

BACNET INTERFACE TST6601



BACnet Interface for TKT66xxC central battery units

We reserve the rights to make modifications without notice.
Copyright © 2024 Teknoware. All rights reserved.
Date: May 14, 2024 | Source:
www.teknoware.fi/en/emergency-lighting/bacnet-interface-tst6601



Teknoware Oy | P.O. Box 19, 15101 Lahti | Ilmarisentie 8, 15200 Lahti Finland
Tel +358 3 883 020 | VAT-number FI01494751 | teknoware.com | emexit@teknoware.com

Product Code	TST6601
Customs Code	85044090
GTIN Code	6438045008653
ETIM Product Class	EC001099

ONE OR MORE OF THESE IS ALSO REQUIRED:

ADDRESSABLE 230 V CENTRAL BATTERY SYSTEMS



Product Code	Nominal Supply Voltage	Number of Output Circuits	Max Load of Circuits (VA)
TKT6608C	1~ N/PE 220-240 VAC, 50/60 Hz	8 x 350 VA / W	
TKT6616C	1~ N/PE 220-240 VAC, 50/60 Hz	16 x 350 VA / W	
TKT6624C	1~ N/PE 220-240 VAC, 50/60 Hz	24 x 350 VA / W	
TKT6608CF	3~ N/PE 220-240/380-415 VAC, 50/60 Hz	8 x 350 VA / W	
TKT6616CF	3~ N/PE 220-240/380-415 VAC, 50/60 Hz	16 x 350 VA / W	
TKT6624CF	3~ N/PE 220-240/380-415 VAC, 50/60 Hz	24 x 350 VA / W	
TKT6608CFP	3~ N/PE 220-240/380-415 VAC, 50/60 Hz	8 x 350 VA / W	
TKT6616CFP	3~ N/PE 220-240/380-415 VAC, 50/60 Hz	16 x 350 VA / W	
TKT6624CFP	3~ N/PE 220-240/380-415 VAC, 50/60 Hz	24 x 350 VA / W	

We reserve the rights to make modifications without notice.
Copyright © 2024 Teknoware. All rights reserved.
Date: May 14, 2024 | Source:
www.teknoware.fi/en/emergency-lighting/bacnet-interface-tst6601

Teknoware Oy | P.O. Box 19, 15101 Lahti | Ilmarisentie 8, 15200 Lahti Finland
Tel +358 3 883 020 | VAT-number FI01494751 | teknoware.com | emexit@teknoware.com



We reserve the rights to make modifications without notice.
Copyright © 2024 Teknoware. All rights reserved.
Date: May 14, 2024 | Source:
www.teknoware.fi/en/emergency-lighting/bacnet-interface-tst6601

Teknoware Oy | P.O. Box 19, 15101 Lahti | Ilmarisentie 8, 15200 Lahti Finland
Tel +358 3 883 020 | VAT-number FI01494751 | teknoware.com | emexit@teknoware.com

