

BATTERY CABLES XJ995



Battery cables for 6,5 Ah batteries, TKT31-, TKT41- and TK23 Central Battery Systems

We reserve the rights to make modifications without notice.
Copyright © 2024 Teknoware. All rights reserved.
Date: April 29, 2024 | Source:
www.teknoware.fi/en/emergency-lighting/battery-cables-xj995

Teknoware Oy | P.O. Box 19, 15101 Lahti | Ilmarisentie 8, 15200 Lahti Finland
Tel +358 3 883 020 | VAT-number FI01494751 | teknoware.com | emexit@teknoware.com



Product Code	XJ995
Customs Code	85044090
GTIN Code	6438045003603
ETIM Product Class	EC002839
Length of Battery Cable	1,5 m

ONE OR MORE OF THESE IS ALSO REQUIRED:

NON-ADDRESSABLE 24 V CENTRAL BATTERY SYSTEMS



Product Code	Nominal Supply Voltage	Number of Output Circuits	Max Load of Circuits (VA)
TKT3122	1~ N/PE 220-240 VAC, 50 Hz	4 x 120 VA / W	
TKT4144	1~ N/PE 220-240 VAC, 50 Hz	8 x 120 VA / W	
TKT4188	1~ N/PE 220-240 VAC, 50 Hz	16 x 120 VA / W	

BATTERIES FOR CENTRAL BATTERY SYSTEMS



Product Code	Product Name	Battery Size (Ah)
TEA020	Sealed Lead Acid Battery TEA020	6,5

We reserve the rights to make modifications without notice.
 Copyright © 2024 Teknoware. All rights reserved.
 Date: April 29, 2024 | Source:
www.teknoware.fi/en/emergency-lighting/battery-cables-xj995

Teknoware Oy | P.O. Box 19, 15101 Lahti | Ilmarisentie 8, 15200 Lahti Finland
 Tel +358 3 883 020 | VAT-number FI01494751 | teknoware.com | emexit@teknoware.com



We reserve the rights to make modifications without notice.
Copyright © 2024 Teknoware. All rights reserved.
Date: April 29, 2024 | Source:
www.teknoware.fi/en/emergency-lighting/battery-cables-xj995

Teknoware Oy | P.O. Box 19, 15101 Lahti | Ilmarisentie 8, 15200 Lahti Finland
Tel +358 3 883 020 | VAT-number FI01494751 | teknoware.com | emexit@teknoware.com

