



CERTIFICATE FI 29162

Our Ref. 277147-2

Product	Emergency luminaire
Type	TWT2984K
Trade mark	TEKNOWARE
Certificate Holder / Manufacturer	Teknoware Oy Ilmarisentie 8 FI-15200 LAHTI, FINLAND
Technical information	FSD-18W-2G11, 220-240V, 50/60Hz, DC 21VA/18W, IP65, Ta: 50°C, Emergency class Z0
Other information	-
The product is certified according to the following standard(s)	EN 60598-2-22:2014 EN 60598-1:2015
Validity	This certificate is valid until 03 June 2020 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.
Directive information	The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.
Date of issue	03 June 2015
Signature	SGS Fimko Ltd Pasi Orreveteläinen Team Leader



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 29162

Manufacturing sites

Teknoware Oy
Ilmarisentie 8
FI-15200 LAHTI, FINLAND

Additional information

-



As shown in the Test Report(s) No(s): 277147-2