


CERTIFICATE FI 29557



Our Ref. 274417-1

Product	Emergency luminaire
Type	TWT8051WK
Trade mark	Teknoware
Certificate Holder / Manufacturer	Teknoware Oy Ilmarisentie 8 FI-15200 LAHTI, FINLAND
Technical information	DB-4,2W/6,6VA; 220-240V; 50/60Hz; class II; IP44; ta 50°C; emergency class Z1
Other information	Centrally supplied maintained luminaire for emergency lighting
The product is certified according to the following standard(s)	EN 60598-1:2015 EN 60598-2-22:2014
Validity	This certificate is valid until 20 May 2021 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.
Directive information	The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.
Date of issue	20 May 2016
Signature	SGS Fimko Ltd  Kari Vesterinen Product Line Manager

This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 29557

Manufacturing sites

Teknoware Oy
Ilmarisentie 8
FI-15200 LAHTI
FINLAND

Additional information

The product has certificate CB FI 9232 issued by SGS Fimko Ltd in accordance with the CB system.



As shown in the Test Report(s) No(s): 274417-1